


SPECIFICATIONS FOR SUPPLY, DELIVERY AND INSTALLATION OF OBSTRUCTION LIGHTS AT TOWERS OF BUILDING 8057 SITE

The offered Obstruction Lights and Installation must meet all of the following requirements:

1. Obstruction Lights Two (2) pcs

- Color of Light: Red
- Operating Voltage from 110VAC – 240 VAC
- Environmental Conditions: Wind Speed of up to 250kph 
- Intensity: 32.5 cd
- Operation: Obstruction lights automatically switch on from dusk to dawn.

2. TERMS, SCOPE AND CONDITIONS

- 2.1 Supply, delivery, and installation of the obstruction lights at Bldg. 8057 site towers and other materials, accessories and incidentals necessary to complete the work.
- 2.2 The obstruction lights shall have at least three years of warranty.
- 2.3 In the event of damage or loss of equipment during the delivery of services or during warranty period, either accidental or due to negligence of the supplier, its company representatives or employees, supplier is obliged to immediately replace, repair, or resolve the issues as may be deemed appropriate by SBMA.

PREPARED BY:



ADRIAN M. DE LEON
UNIT HEAD - GROUND ELECTRONICS

NOTED BY:



RUEL P. BOBADILLA
OIC, PLANNING & ENG'G.

APPROVED BY:



For:
ZHARREX R. SANTOS
MANAGER, SBIA