

Republic of the Philippines
SUBIC BAY METROPOLITAN AUTHORITY

TECHNICAL SPECIFICATIONS
FOR THE

SERVICES AND MATERIALS
✓ PREVENTIVE **MAINTENANCE OF AIR CONDITIONING**
UNITS INSTALLED AT VARIOUS BUILDINGS OF SBMA

FOREWORD

1. SCOPE OF WORK

The CONTRACTOR'S services shall perform a semi-annual preventive maintenance of all air conditioning units installed in various buildings of Subic Bay Metropolitan Authority. It shall be inclusive of all labor, tools, and necessary equipment to maintain the AC and Air cooler units in serviceable condition throughout the contract period.

1.1 SPECIFIC TASKS

- 1.1.1 Check for any unusual noise and vibration
- 1.1.2 Check anti-vibration mounting
- 1.1.3 Check the compressor current (Amperes)
- 1.1.4 Clean Condenser & Evaporator coils with approved chemical
- 1.1.5 Check Condenser fan blades
- 1.1.6 Check Evaporator fan blower
- 1.1.7 Check the fan motor operation for free movement
- 1.1.8 Check thermostat for proper operation (Temp. setting)
- 1.1.9 Check selector switch
- 1.1.10 Check and tighten all terminals
- 1.1.11 Clean air filter
- 1.1.12 Check refrigerant level
- 1.1.13 Provide a sticker after cleaning each unit
- 1.1.14 Other activities not stated but necessary in the AC Unit maintenance/cleaning and to report defects found to the Maintenance Division

2. APPROVED BUDGET FOR THE CONTRACT (ABC)

Nine hundred twenty-five thousand four hundred twenty pesos (**Php 925,420**).

3. QUALIFICATIONS

The Bidder must have a minimum of at least five (3) years of experience in doing business of providing preventive maintenance on Air Conditioning units.

4. CONTRACT PERIOD

The preventive maintenance service *✓ must be completed within 2 years* comprising of 2 cycle cleaning within the said period. Each cycle should be completed not later than 50 working days.

5. MANNER OF PAYMENT / BILLING

- 5.1 The Service Provider shall submit to SBMA a picture of their work during and after the services, copies of receipted invoices, vouchers and other appropriate supporting materials such as acceptance by the custodian of aircon units being serviced, after ten (10) working days.
- 5.2 SBMA may give written notice to the Service Provider within five (5) working days specifying in details deficiencies in the services. The Service Provider shall thereupon promptly make any necessary corrections within a maximum period of ten (10) days, and upon completion of such corrections, the foregoing process shall be repeated.
- 5.3 The service shall be paid through monthly progress accomplishment.
- 5.4 The compensation for the supervisor overseeing the services is included in the admin cost.
- 5.5 In the event that any air conditioning units are not cleaned as per the agreement, corresponding deductions shall be computed based on AC unit type/size and quantity.

6. LOCATIONS

The list of buildings/facilities to be rendered.

	LOCATION	DEPARTMENT	POWER OUTPUT/ COOLING CAPACITY	BRAND	TYPE	SBMA PROPERTY NO./ SERIAL NO.	REMARKS
	AIRPORT						
1	ELECTRICAL ROOM	AIRPORT	24000 BTU	KOPPEL	WALL MOUNTED	200-18288	CONVENTIONAL
2	CCTV	AIRPORT	18200 BTU	KOPPEL	WALL MOUNTED	200-18280	CONVENTIONAL
3	CCTV	AIRPORT	2.0 HP	HISENSE	WALL MOUNTED	200-22377	CONVENTIONAL
4	STORAGE ROOM	AIRPORT	1.0 HP	HISENSE	WALL MOUNTED	200-22381	CONVENTIONAL
5	ENGINEERING	AIRPORT	2.0 HP	HISENSE	WALL MOUNTED	200-22383	CONVENTIONAL
6	CONFERENCE	AIRPORT	24000 BTU	KOPPEL	WALL MOUNTED	200-18286	CONVENTIONAL
7	CONFERENCE	AIRPORT	2.0 HP	HISENSE	WALL MOUNTED	200-22387	CONVENTIONAL
8	ADMINISTRATOR	AIRPORT	24000 BTU	KOPPEL	WALL MOUNTED	200-18292	CONVENTIONAL
9	ASMU	AIRPORT	1.0 HP	HISENSE	WALL MOUNTED	200-22389	CONVENTIONAL
10	PROCUREMENT	AIRPORT	24000 BTU	KOPPEL	WALL MOUNTED	200-18290	CONVENTIONAL
11	MANAGER OFFICE	AIRPORT	24000 BTU	KOPPEL	WALL MOUNTED	200-18282	CONVENTIONAL
12	ADMINISTRATOR	AIRPORT	2.0 HP	DAIKIN	WALL MOUNTED	200-18284	CONVENTIONAL
13	OPERATIONS DEVISION (RM 147)	AIRPORT	2.5 HP	CARRIER	CEILING MOUNTED CASSETTE	200-19216	CONVENTIONAL
14	ENGINEERING	AIRPORT	2.5 HP	CARRIER	CEILING MOUNTED CASSETTE	200-19214	CONVENTIONAL
15	OPERATIONS DEVISION	AIRPORT	2.5 HP	CARRIER	CEILING MOUNTED CASSETTE	200-19218	CONVENTIONAL
16	PASS CONTROL OFFICE	AIRPORT	2.5 HP	CARRIER	CEILING MOUNTED CASSETTE	200-19222	CONVENTIONAL
17	TREASURY	AIRPORT	1.5 HP	KOPPEL	WALL MOUNTED	200-19234	CONVENTIONAL
18	OPERATIONS (RM 113)	AIRPORT	24000 BTU	KOPPEL	WALL MOUNTED	N/A	CONVENTIONAL
19	RAMP	AIRPORT	24000 BTU	KOPPEL	WALL MOUNTED	200-18300	CONVENTIONAL
20	OPERATIONS (RM 241)	AIRPORT	1.5 HP	HISENSE	WALL MOUNTED	200-22358	CONVENTIONAL
21	OPERATIONS (RM 241)	AIRPORT	3 TR	ALENAIRE	FLOOR MOUNTED	N/A	CONVENTIONAL
22	OPERATIONS (RM 242)	AIRPORT	1.0 HP	KOPPEL	WALL MOUNTED	200-18270	CONVENTIONAL
23	PHIL. 2000 LOUNGE	AIRPORT	2.5 HP	CARRIER	CEILING MOUNTED CASSETTE	200-19210	CONVENTIONAL
24	FIREMAN	AIRPORT	2.0 HP	CHIGO	WINDOW	200-21279	CONVENTIONAL
25	FIREMAN	AIRPORT	2.0 HP	GREE	WINDOW	200-22365	INVERTER
26	FIREMAN	AIRPORT	1.0 HP	LG	WINDOW	200-20934	CONVENTIONAL
27	FIREMAN	AIRPORT	2.5 HP	CARRIER	WALL MOUNTED	200-19222	CONVENTIONAL
28	SECURITY	AIRPORT	5 TR	HITACHI	FLOOR MOUNTED	200-13725	CONVENTIONAL
29	SECURITY	AIRPORT	2.0 HP	HITACHI	WINDOW	200-17193	CONVENTIONAL
30	ARMORY	AIRPORT	3 TR	ALENAIRE	FLOOR MOUNTED	200-16826	CONVENTIONAL
31	ARMORY	AIRPORT	2.0 HP	CHIGO	WINDOW	200-21285	CONVENTIONAL
32	CAAP ANSO	AIRPORT	2.5 HP	TECO	WALL MOUNTED	200-23123	CONVENTIONAL
33	CAAP ANSO	AIRPORT	2.5 HP	TECO	WALL MOUNTED	200-23125	CONVENTIONAL
34	G ELECTROMNICS	AIRPORT	3 HP	ALLEN AIR	FLOOR MOUNTED	N/A	CONVENTIONAL
35	ATSO	AIRPORT	2.5 HP	TECO	WALL MOUNTED	N/A	CONVENTIONAL
36	TOWER CAB	AIRPORT	2.5 HP	MITSUBISHI	WALL MOUNTED	200-23189	CONVENTIONAL
37	TOWER CAB	AIRPORT	2.5 HP	MITSUBISHI	WALL MOUNTED	200-23187	CONVENTIONAL
38	RADAR SITE	AIRPORT	2.0 HP	DAIKIN	WALL MOUNTED	200-23191	CONVENTIONAL
39	RADAR SITE	AIRPORT	2.0 HP	DAIKIN	WALL MOUNTED	200-23193	CONVENTIONAL
40	RADAR SITE	AIRPORT	2.0 HP	DAIKIN	WALL MOUNTED	200-23195	CONVENTIONAL
	BLDG 255						
1	2nd Floor Room 223	PROJECT DEVELOPMENT DIVISION	13,200 KJ/hr	Carrier	Window	200-11896	CONVENTIONAL
2	2nd Floor Room 220	TREASURY DEPARTMENT	18,710 KJ/HR	GREE	WINDOW	200-22226	INVERTER
3	2nd Floor Room 229	DEPUTY ADMINSTRATOR	18,710 KJ/HR	GREE	WINDOW	200-22219	INVERTER
4	2nd Floor Room 223	PROJECT DEVELOPMENT DIVISION	18,710 KJ/HR	GREE	WINDOW	200-22218	INVERTER
5	2nd Floor Room 224	UTILITIES MANAGEMENT OFFICE	13,200 KJ/hr	Carrier	Window	200-11384	CONVENTIONAL
6	2nd Floor Room 228	ENGINEERING ADMIN DEPARTMENT	18,710 KJ/HR	GREE	WINDOW	200-22215	INVERTER
7	2nd Floor Room 230	TECHNICAL SERVICES DIVISION	18,710 KJ/HR	GREE	WINDOW	200-22213	INVERTER
8	2nd Floor Room 228	ENGINEERING ADMIN DEPARTMENT	19,518 KJ/HR	Condura	Window	N/A	CONVENTIONAL
9	2nd Floor Room 230	TECHNICAL SERVICES DIVISION	18,710 KJ/HR	GREE	WINDOW	200-22212	INVERTER
10	2nd Floor Room 229	DEPUTY ADMINSTRATOR	2.0HP	Samsung	Window	200-19872	CONVENTIONAL
11	2nd Floor Room 230	TECHNICAL SERVICES DIVISION	18,710 KJ/HR	GREE	WINDOW	200-22216	INVERTER
12	2nd Floor Room 228	ENGINEERING ADMIN DEPARTMENT	13,188 KJ/HR	Condura	Window	200-19356	CONVENTIONAL
13	2nd Floor Room 205	LEGAL DEPARTMENT	1.5 HP	Kolin	Window	200-18257	CONVENTIONAL
14	2nd Floor Room 223	PROJECT DEVELOPMENT DIVISION	18,710 KJ/HR	GREE	WINDOW	200-22217	INVERTER
15	2nd Floor Room 223	PROJECT DEVELOPMENT DIVISION	18,710 KJ/HR	GREE	WINDOW	200-22214	INVERTER
16	2nd Floor Room 229	DEPUTY ADMINSTRATOR	18,710 KJ/HR	GREE	WINDOW	200-22220	INVERTER
17	2nd Floor Room 205	LEGAL DEPARTMENT	13,800 KJ/hr	Condura	Window	200-18664	
18	2nd Floor Room 205	LEGAL DEPARTMENT	13,800 KJ/hr	Condura	Window	N/A	
19	2nd Floor Room 213	RECORDS (TREASURY)	1.0 HP	Kolin	Window	200-18266	
20	2nd Floor Room 215	RECORDS (ENGINEERING)	13,188 KJ/HR	Carrier	Window	200-18833	
21	2nd Floor Room 204	LEGAL DEPARTMENT	13,188 KJ/hr	Condura	Window	200-19376	
22	2nd Floor Room 220	TREASURY DEPARTMENT	1.5 HP	GREE	WINDOW	200-22225	INVERTER
23	2nd Floor Room 209	COMMISSION ON AUDIT	1.5 HP	Carrier	Window	200-19327	
24	2nd Floor Room 210	LABOR DEPARTMENT	1.5 HP	GREE	WINDOW	200-22245	INVERTER
25	2nd Floor Room 218	CONFERENCE ROOM	19,600 KJ/HR	Carrier	Window	200-21131	
26	2nd Floor Room 218	CONFERENCE ROOM	19,600 KJ/HR	Carrier	Window	200-21130	
27	2nd Floor Room 209	COMMISSION ON AUDIT	1.5 HP	Carrier	Window	200-21068	
28	2nd Floor Room 203	LEGAL DEPARTMENT	13,188 KJ/HR	Carrier	Window	200-20777	
29	2nd Floor Room 210	LABOR DEPARTMENT	9,100 KJ/HR	LG	Window	200-19522	
30	2nd Floor Room 209	COMMISSION ON AUDIT	1.5 HP	Carrier	Window	200-19428	
31	2nd Floor Room 209	COMMISSION ON AUDIT	1.5 HP	Carrier	Window	N/A	*2 UNITS
32	2nd Floor Room 202	RECORDS (LEGAL)	19,600 KJ/HR	Carrier	Window	200-09849	

32	2nd Floor Room 210	LABOR DEPARTMENT	1.5 HP	GREE	WINDOW	200-22246	INVERTER
33	2nd Floor Room 207	LEGAL DEPARTMENT	1.5 HP	Kolin	Window	N/A	
34	2nd Floor Room 209	COMMISSION ON AUDIT	19,600 KJ/HR	Carrier	Window	200-15897	
35	Ground Floor Room 127	LABOR DEPARTMENT	18,710 KJ/hr	GREE	WINDOW	200-22242	INVERTER
36	Ground Floor Room 136	LEGAL DEPARTMENT	2.0 HP	LG	Window	200-15577	
37	Ground Floor Room 136	LEGAL DEPARTMENT	2.0 HP	CARRIER	Window	200-17982	
38	Ground Floor Room 138	LABOR DEPARTMENT	18,710 KJ/hr	GREE	WINDOW	200-22240	INVERTER
39	Ground Floor Room 125	LABOR DEPARTMENT	18,710 KJ/hr	GREE	WINDOW	200-22239	INVERTER
40	Ground Floor Room 125	LABOR DEPARTMENT	2.0 HP	CARRIER	Window	200-21243	
41	Ground Floor Room 132	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22229	INVERTER
42	Ground Floor Room 134	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22231	INVERTER
43	Ground Floor Room 130	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22259	INVERTER
44	Ground Floor Room 130	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22238	INVERTER
45	Ground Floor Room 130	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22228	INVERTER
46	Ground Floor Room 130	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22227	INVERTER
47	Ground Floor Room 124	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22237	INVERTER
48	Ground Floor Room 124	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22236	INVERTER
49	Ground Floor Room 130	FINANCIAL PLANNING AND BUDGET	18,710 KJ/hr	GREE	WINDOW	200-22230	INVERTER
50	Ground Floor Room 138	LABOR DEPARTMENT	18,710 KJ/hr	GREE	WINDOW	200-22241	INVERTER
51	Ground Floor Room 138	LABOR DEPARTMENT	2.0 HP	CARRIER	Window	200-17685	
52	Ground Floor Room 116	LABOR DEPARTMENT HEAD	19,600 KJ/HR	CARRIER	Window	200-20793	
53	Ground Floor Room 116	LABOR DEPARTMENT HEAD	18,710 KJ/hr	GREE	WINDOW	200-22243	INVERTER
54	Ground Floor Room 109	SOCIAL DEPARTMENT DEVISION	1.0 HP	LG	Window	200-19524	
55	Ground Floor Room 107	MEDIA PRODUCTION DEPARTMENT	18,710 KJ/hr	GREE	WINDOW	200-22240	INVERTER
56	Ground Floor Room 107	MEDIA PRODUCTION DEPARTMENT	19,600 KJ/HR	CARRIER	Window	200-19446	
57	Ground Floor Room 112	INTERNAL AUDIT SERVICE	1.0 HP	KOLIN	Window	200-17795	
58	Ground Floor Room 112	INTERNAL AUDIT SERVICE	18,710 KJ/hr	GREE	WINDOW	200-22240	INVERTER
59	Ground Floor Room 112	INTERNAL AUDIT SERVICE	18,710 KJ/hr	GREE	WINDOW	200-22239	INVERTER
60	Ground Floor Room 112	INTERNAL AUDIT SERVICE	18,710 KJ/hr	GREE	WINDOW	200-22224	INVERTER
61	Ground Floor Room 112	INTERNAL AUDIT SERVICE	19,600 KJ/HR	CARRIER	Window	200-17123	
62	Ground Floor Room 112	INTERNAL AUDIT SERVICE	18,710 KJ/hr	GREE	WINDOW	200-22241	INVERTER
63	Ground Floor Room 105	PUBLIC RELATION OFFICE	1.0 HP	KOLIN	Window	200-18258	
64	Ground Floor Room 105	PUBLIC RELATION OFFICE	18,710 KJ/hr	GREE	WINDOW	200-22238	INVERTER
65	Ground Floor Room 105	PUBLIC RELATION OFFICE	1.0 HP	CARRIER	Window	200-19427	
66	Ground Floor Room 105	PUBLIC RELATION OFFICE	18,710 KJ/hr	GREE	WINDOW	200-22237	INVERTER
67	HR MANAGEMENT	DEPARTMENT MANAGER	18,710 KJ/hr	GREE	WINDOW	200-22294	INVERTER
68	HR MANAGEMENT	CONFERENCE	19,300 KJ/HR	LG	Window	200-15752	
69	HR MANAGEMENT	FILE ROOM	19,600 KJ/HR	CONDURA	Window	200-20734	
70	HR MANAGEMENT	MANAGEMENT SECTION	18,710 KJ/hr	GREE	WINDOW	200-22295	INVERTER
71	HR MANAGEMENT	MANAGEMENT SECTION	18,710 KJ/hr	GREE	WINDOW	200-22296	INVERTER
72	HR MANAGEMENT	MANAGEMENT SECTION	18,710 KJ/hr	GREE	WINDOW	200-22297	INVERTER
73	HR MANAGEMENT	ADMINISTRATIVE SECRETARY	18,710 KJ/hr	GREE	WINDOW	200-22287	INVERTER
74	2nd Floor PPMD	PPMD	18,710 KJ/HR	GREE	WINDOW	200-22255	INVERTER
75	2nd Floor PPMD	PPMD	18,710 KJ/HR	GREE	WINDOW	200-22284	INVERTER
76	2nd Floor PPMD	PPMD	19,600 KJ/HR	Carrier	Window	200-19839	
77	2nd Floor PPMD	PPMD	18,710 KJ/HR	GREE	WINDOW	200-22252	INVERTER
78	2nd Floor PPMD	PPMD	3TR	Carrier	Floor mounted	200-17855	
79	2nd Floor PPMD	PPMD	19,600 KJ/HR	Carrier	Window	200-19549	
80	2nd Floor PPMD	PPMD	18,710 KJ/HR	GREE	WINDOW	200-22254	INVERTER
81	2nd Floor PPMD	PPMD	18,710 KJ/HR	GREE	WINDOW	200-22253	INVERTER
82	2nd Floor PPMD	PPMD	18,710 KJ/HR	GREE	WINDOW	200-22251	INVERTER
83	2nd Floor PPMD	PPMD	19,600 KJ/HR	Carrier	Window	200-21140	
84	2nd Floor PPMD	PPMD	1.0 HP	Carrier	Window	200-19422	
85	2nd Floor Room 230	TECHNICALSERVICE DIVISION	3TR	Koppel	Floor mounted	200-22502	
86	2nd Floor Room 224	UTILITIES MANAGEMENT OFFICE	2.0 HP	Carrier	Wall mounted	200-17800	
87	Ground Floor RM 107	MEDIA PRODUCTION DEPARTMENT	2.0 HP	HISENSE	Wall mounted	200-22446	
88	Benefits Section	HR DEPARTMENT	3TR	Carrier	Floor mounted	200-17005	
89	Ground Floor RM 112	INTERNAL AUDIT SERVICE	2.5 HP	HISENSE	Wall mounted	200-22404	
90	Ground Floor RM 136	OFFICE DEPUTY ADMINISTRATOR	1.5 HP	Carrier	Wall mounted	200-11928	
91	SERVER ROOM	MIS	1.0 HP	LG	WINDOW	200-20763	
BLDG 275							
1	2nd Floor Conference room	MTD	19,600 KJ/HR	Carrier	Window	200-17688	
2	2nd Floor Admin room	MTD	13,200 KJ/hr	Carrier	Window	200-14807	
3	2nd Floor Near Exit	MTD	19,600 KJ/HR	Carrier	Window	200-17271	
4	2nd Floor Management section	MTD	10,022KJ/HR	Condura	Window	200-21080	
5	2nd Floor Manager room	MTD	1.5HP	Carrier	Window	200-02598	
6	2nd Floor Management section	MTD	18,900 KJ/HR	Carrier	Window	200-19415	
7	2nd Floor MIC BASE	MTD	1HP	National	Window	2110829948	
8	2nd Floor Management section	MTD	10,022KJ/HR	Condura	Window	200-21079	
9	2nd Floor Division Chief room	MTD	19,518 KJ/HR	Carrier	Window	200-02597	
10	2nd Floor MIC BASE	MTD	1HP	National	Window	27192813	
11	2nd Floor Management section	MTD	1.5HP	National	Window	200-08396	
12	2nd Floor Management section	MTD	13,188 KJ/HR	Condura	Window	200-19356	
13	Tool room	MTD	2.0HP	Carrier	Window	200-19355	
14	Tool room	MTD	7,500 KJ/HR	LG	Window	200-21014	
15	Green Brigade Office	MTD	2.0HP	National	Window	1042713977	
16	Green Brigade Office	MTD	2.0HP	Carrier	Window	N/A	
17	Green Brigade Office	MTD	9,100 KJ/HR	LG	Window	200-19809	
18	EPSU Section	MTD	18,900 KJ/HR	Carrier	Window	200-19838	
19	Lock Smith room	MTD	13,200 KJ/hr	Carrier	Window	200-15427	
20	AC Supervisor room	MTD	2.5 HP	Hitachi	Window	200-19594	
21	Structural Room	MTD	2HP	N/A	Window	N/A	

	BLDG 657						
1	MANAGER	LAW ENFORCEMENT DIVISON	2.5 HP	HITACHI	WINDOW	200-22027	INVERTER
2	OPCC	LAW ENFORCEMENT DIVISON	2.0 HP	GREE	WINDOW	200-22250	INVERTER
3	PSCRD	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22355	INVERTER
4	OPNS	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22348	INVERTER
5	ADMIN	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22432	INVERTER
6	ADMIN	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22433	INVERTER
7	LOGISTICS	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22350	INVERTER
8	LOGISTICS	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22347	INVERTER
9	LOGISTICS	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22351	INVERTER
10	TRAFFIC	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22353	INVERTER
11	INFORMATION	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22346	INVERTER
12	INFORMATION	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22347	INVERTER
13	SLED	LAW ENFORCEMENT DIVISON	19,300 KJ/HR	CARRIER	Window	200-14808	
14	GBD	LAW ENFORCEMENT DIVISON	19,300 KJ/HR	CONDURA	Window	200-20586	
15	GBD	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22354	INVERTER
16	RECORDS	LAW ENFORCEMENT DIVISON	1.0 HP	LG	Window	4037ABN00525	
17	ARMORY	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22349	INVERTER
18	ARMORY	LAW ENFORCEMENT DIVISON	1.0 HP	LG	Window	4037ABN00526	
19	OFTD	LAW ENFORCEMENT DIVISON	19,300 KJ/HR	CONDURA	Window	200-21574	
20	PSB	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22352	INVERTER
21	OIC INTEL	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22369	INVERTER
22	SOB	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22367	INVERTER
23	SOB	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22368	INVERTER
24	SUPPLY ROOM	LAW ENFORCEMENT DIVISON	1.5 HP	LG	Window	200-20758	
25	ADMIN OFFICE	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22370	INVERTER
26	INFORMATION	LAW ENFORCEMENT DIVISON	19,300 KJ/HR	CARRIER	Window	200-2576	
27	INFORMATION	LAW ENFORCEMENT DIVISON	3TR	CARRIER	FLOOR MOUNTED	200-22066	
28	BAS	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22371	INVERTER
29	GCB	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22358	INVERTER
30	WCPB	LAW ENFORCEMENT DIVISON	9,600 KJ/HR	CARRIER	Window	200-19380	
31	WCPB	LAW ENFORCEMENT DIVISON	9,300 KJ/HR	LG	Window	200-20793	
32	MANAGERS OFFICE	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22373	INVERTER
33	GCB	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22372	INVERTER
34	GCB	LAW ENFORCEMENT DIVISON	1.5 HP	KOPPEL	WALL MOUNTED	N/A	
35	BRIEFING ROOM	LAW ENFORCEMENT DIVISON	3TR	CARRIER	FLOOR MOUNTED	N/A	
36	TRAINING CENTER	LAW ENFORCEMENT DIVISON	7,300 BTU	LG	WINDOW	4037AEJ00423	
37	TRAINING CENTER	LAW ENFORCEMENT DIVISON	7,300 BTU	LG	WINDOW	4037AEJ00516	
38	TRAINING CENTER	LAW ENFORCEMENT DIVISON	19,300 KJ/HR	CONDURA	WINDOW	200-19753	
39	TRAINING CENTER	LAW ENFORCEMENT DIVISON	2 HP	N/A	WINDOW	N/A	
40	TRAINING CENTER	LAW ENFORCEMENT DIVISON	2 HP	N/A	WINDOW	N/A	
41	TRAINING CENTER	LAW ENFORCEMENT DIVISON	2 HP	N/A	WINDOW	N/A	
42	TRAINING CENTER	LAW ENFORCEMENT DIVISON	2 HP	N/A	WINDOW	N/A	
43	OFFICE	LAW ENFORCEMENT DIVISON	18,710 KJ/HR	GREE	WINDOW	200-22356	INVERTER
	BLDG 709						
1	RECEIVING SEC.	PPMD	24,000 KJ/HR	QUBE	WALL MOUNTED	200-22702	
2	RECEIVING SEC.	PPMD	13,210 KJ/HR	KOLIN	WINDOW	200-22691	INVERTER
3	WAREHOUSE SEC.	PPMD	13,210 KJ/HR	KOLIN	WINDOW	4811990410	INVERTER
4	WAREHOUSE SEC.	PPMD	13,210 KJ/HR	KOLIN	WINDOW	200-22692	INVERTER
5	FILE ROOM	PPMD	13,210 KJ/HR	KOLIN	WINDOW	200-22688	INVERTER
6	PANTRY	PPMD	13,210 KJ/HR	KOLIN	WINDOW	200-22689	INVERTER
7	ADMIN	PPMD	13,210 KJ/HR	KOLIN	WINDOW	200-22687	INVERTER
8	INVENTORY SEC.	PPMD	3TR	KOLIN	FLOOR MOUNTED	200-22704	
9	INVENTORY SEC.	PPMD	3TR	KOLIN	FLOOR MOUNTED	200-22706	
10	SYSTEM ADMIN	PPMD	1.0 HP	LG	Window	200-20672	
11	MANAGERS OFFICE	PPMD	18,710 KJ/HR	KOLIN	WINDOW	200-22686	INVERTER
12	ISSUANCE SEC.	PPMD	13,210 KJ/HR	KOLIN	WINDOW	200-22690	INVERTER
13	YARD	PPMD	2.0 HP	CARRIER	Window	200-19550	
14	YARD	PPMD	2.0 HP	CARRIER	Window	200-19450	
15	ISSUANCE SEC.	PPMD	3TR	CARRIER	FLOOR MOUNTED	200-17200	
16	ISSUANCE SEC.	PPMD	3TR	CARRIER	FLOOR MOUNTED	200-15935	
17	SUPPLY OFFICER	PPMD	24,000 KJ/HR	QUBE	WALL MOUNTED	200-20700	
18	CONFERENCE	PPMD	24,000 KJ/HR	QUBE	WALL MOUNTED	200-22694	
19	ADMIN	PPMD	1.0 HP	QUBE	WALL MOUNTED	200-22698	
	FIRE DEPARTMENT						
1	LOBBY	FIRE DEPARTMENT	2760 WATTS	TECO	WINDOW	N/A	INVERTER
2	DEPUTY CHIEF	FIRE DEPARTMENT	2760 WATTS	TECO	WINDOW	N/A	INVERTER
3	ASSISTANT FIRE CHIEF	FIRE DEPARTMENT	2760 WATTS	TECO	WINDOW	N/A	INVERTER
4	CONFERENCE	FIRE DEPARTMENT	2.5 HP	LG	WINDOW	N/A	INVERTER
5	MEDICS QUARTERS	FIRE DEPARTMENT	2760 WATTS	TECO	WINDOW	N/A	INVERTER
6	FIRE PREVENTION CHIEF	FIRE DEPARTMENT	12000 BTU	TECO	WALL MOUNTED	ZL91700031	
7	QUARTERS	FIRE DEPARTMENT	18000 BTU	TECO	WALL MOUNTED	ZL91800091	
8	QUARTERS	FIRE DEPARTMENT	18000 BTU	TECO	WALL MOUNTED	ZL91800092	
9	FIRE CHIEF	FIRE DEPARTMENT	2.5 HP	LG	WINDOW	N/A	INVERTER
10	TRAINING CONFERENCE	FIRE DEPARTMENT	2.5 HP	LG	WINDOW	N/A	INVERTER
11	FIRE CHIEF	FIRE DEPARTMENT	12000 BTU	TECO	WALL MOUNTED	ZL91700028	
12	ADMIN	FIRE DEPARTMENT	22000 BTU	TECO	WALL MOUNTED	ZL91900043	
13	QUARTERS	FIRE DEPARTMENT	18000 BTU	TECO	WALL MOUNTED	ZL91800093	
14	TRAINING CONFERENCE	FIRE DEPARTMENT	2.5 HP	LG	WINDOW	N/A	INVERTER
15	ALARM ROOM	FIRE DEPARTMENT	2760 WATTS	TECO	WINDOW	N/A	INVERTER
16	LOCKER ROOM	FIRE DEPARTMENT	12000 BTU	TECO	WALL MOUNTED	ZL91700022	

	BLDG 229						
1	BOARD ROOM		3 TR	N/A	SUSPENDED CEILING	N/A	
2	BOARD ROOM		3 TR	N/A	SUSPENDED CEILING	N/A	
3	MINI BOARD ROOM		2.0 HP	N/A	WALL MOUNTED	N/A	
4	102 DIRECTOR		2.0 HP	CARRIER	WALL MOUNTED	200-17974	
5	102 DIRECTOR		2.0 HP	CARRIER	WALL MOUNTED	200-12237	
6	RM 107		3 TR	CARRIER	FLOOR MOUNTED	200-16191	
7	RM 107		1.0 HP	CARRIER	WALL MOUNTED	200-11929	
8	RM 106		2.0 HP	KOPPEL	WALL MOUNTED	200-95958	
9	RM 108		3 TR	KOPPEL	FLOOR MOUNTED	200-22436	
10	RM 108		3 TR	MIDEA	FLOOR MOUNTED	200-95956	
11	RM 108		3 TR	MIDEA	FLOOR MOUNTED	200-95954	
12	RM 108		1.0 HP	CARRIER	WALL MOUNTED	200-17639	
13	2ND FLR. WAITING AREA		18710 KJ/HR	GREE	WINDOW	200-22395	INVERTER
14	2ND FLR. WAITING AREA		18710 KJ/HR	GREE	WALL MOUNTED	200-21689	
15	2ND FLR. PANTRY		1.0 HP	CARRIER	WALL MOUNTED	200-17035	
16	BOARD SECRETARY	BOARD MEMBERS	1.5 HP	HISENSE	WALL MOUNTED	200-22450	
17	BOARD SECRETARY	BOARD MEMBERS	1.5 HP	HISENSE	WALL MOUNTED	200-22498	
18	BOARD SECRETARY	BOARD MEMBERS	1.5 HP	HISENSE	WALL MOUNTED	200-22496	
19	BOARD SECRETARY	BOARD MEMBERS	3 TR	KOPPEL	FLOOR MOUNTED	200-22210	
20	111		2.0 HP	CARRIER	WINDOW	51PMXRACCAR19KED	
21	209 DA FOR A		3 TR	KOPPEL	FLOOR MOUNTED	200-22428	
22	209 DA FOR A		2.5 HP	HISENSE	WALL MOUNTED	200-22375	
23	211 DAF		2.5 HP	HISENSE	WALL MOUNTED	200-22424	
24	211 DAF		1.0 HP	CARRIER	WALL MOUNTED	200-17170	
25	109 SDA		2.0 HP	HISENSE	WALL MOUNTED	200-22414	
26	109 SDA		2.0 HP	PANASONIC	WALL MOUNTED	200-16969	
27	213 TREASURY	TREASURY	1.0 HP	KOPPEL	WALL MOUNTED	200-22022	
28	213 TREASURY	TREASURY	2.0 HP	KOPPEL	WALL MOUNTED	200-95981	
29	213 TREASURY	TREASURY	1.0 HP	KOLIN	WINDOW	200-18246	INVERTER
30	213 TREASURY	TREASURY	2.5 HP	KOPPEL	WALL MOUNTED	200-22024	
31	213 TREASURY	TREASURY	3 TR	CARRIER	FLOOR MOUNTED	200-17199	
32	GROUND FLOOR		1.5 HP	HISENSE	WALL MOUNTED	N/A	
33	3RD FLOOR	ACCOUNTING	90000 KJ/HR	CARRIER	FLOOR MOUNTED	200-17135	
34	CHAIRMAN'S OFFICE	CHAIRMAN	23757 KJ/HR	MIDEA	WALL MOUNTED	96190120102	
35	CHAIRMAN'S OFFICE	CHAIRMAN	1.0 HP	MIDEA	WALL MOUNTED	18A060170335	
36	CHAIRMAN'S OFFICE	CHAIRMAN	19620 KJ/HR	MIDEA	WALL MOUNTED	387120150175	
37	CHAIRMAN'S OFFICE	CHAIRMAN	2.0 HP	MIDEA	WALL MOUNTED	108050130035	
38	CHAIRMAN'S OFFICE	CHAIRMAN	1.0 HP	MIDEA	WALL MOUNTED	108050130017	
39	CHAIRMAN'S OFFICE	CHAIRMAN	2.5 HP	MIDEA	WALL MOUNTED	34179996100	
40	CHAIRMAN'S OFFICE	CHAIRMAN	30280 KJ/HR	MIDEA	WALL MOUNTED	108050130037	
41	ACCOUNTING	ACCOUNTING	1990 WATTS	HISENSE	WALL MOUNTED	200-22418	
42	ACCOUNTING	ACCOUNTING	3 TR	KOPPEL	FLOOR MOUNTED	200-22422	
43	ACCOUNTING	ACCOUNTING	3 TR	KOPPEL	FLOOR MOUNTED	200-22420	
44	ACCOUNTING	ACCOUNTING	2.5 HP	KOPPEL	WALL MOUNTED	200-19245	
	BLDG 280						
1	LABORATORY	PHSD	2.0 HP	CARRIER	WINDOW	200-19837	
2	LABORATORY	PHSD	1.0 HP	LG	WINDOW	200-21020	
3	DENTAL CLINIC	PHSD	2.0 HP	CARRIER	WINDOW	200-11895	
4	DA'S OFFICE	PHSD	1.0 HP	NATIONAL	WINDOW	8N2434534	
5	DENTAL STOCK	PHSD	1.0 HP	CONDURA	WINDOW	200-20744	
6	ULTRASOUND RM	PHSD	1.0 HP	LG	WINDOW	200-20673	
7	X-RAY PANTRY	PHSD	1.0 HP	FUJIDENZO	WINDOW	200-23049	
8	PHARMACY	PHSD	2.0 HP	GREE	WINDOW	200-22473	INVERTER
9	DRUG TEST RM	PHSD	1.0 HP	CONDURA	WINDOW	200-20745	
10	X-RAY ROOM NEW BLDG.	PHSD	1.0 HP	KOPPEL	WINDOW	200-21071	
11	X-RAY MOBILE	PHSD	1.0 HP	IDEC	WINDOW	200-21123	
12	X-RAY MOBILE	PHSD	1.5 HP	IDEC	WALL MOUNTED	200-21133	
13	MALE QUARTERS	PHSD	2.0 HP	CONDURA	WINDOW	200-21083	
14	MALE QUARTERS	PHSD	18710 KJ/HR	GREE	WINDOW	200-22471	INVERTER
15	ADMIN	PHSD	18710 KJ/HR	GREE	WINDOW	200-22474	INVERTER
16	LOBBY	PHSD	1.0 HP	KELVINATOR	WINDOW	200-16886	
17	OHSD	PHSD	2.0 HP	KOPPEL	WINDOW	200-21070	
18	OHSD	PHSD	18710 KJ/HR	GREE	WINDOW	200-22366	INVERTER
19	WAITING AREA	PHSD	3 TR	CARRIER	FLOOR MOUNTED	200-08780	
20	DAHS	PHSD	18710 KJ/HR	GREE	WINDOW	200-22475	INVERTER
21	DAHS	PHSD	2.0 HP	NATIONAL	WINDOW	200-18066	
22	STORAGE	PHSD	18710 KJ/HR	GREE	WINDOW	200-22470	INVERTER
23	STORAGE	PHSD	18710 KJ/HR	GREE	WINDOW	200-22448	INVERTER
24	ADMIN	PHSD	2.5 HP	DAIKIN	WALL MOUNTED	200-23041	
25	PHARMACY	PHSD	1.0 HP	CARRIER	WINDOW	200-15572	
26	FEMALE QUARTERS	PHSD	18710 KJ/HR	GREE	WINDOW	200-22486	INVERTER
27	CONSULTATION AREA	PHSD	18710 KJ/HR	GREE	WINDOW	200-22472	INVERTER
28	RECORDS	PHSD	1.5 HP	CONDURA	WINDOW	200-20581	
29	LOBBY	PHSD	3 TR	KOPPEL	FLOOR MOUNTED	200-22322	
	BLDG 332						
1	LOBBY	LADD	25,030 KJ/HR	EVEREST	WALL MOUNTED	255TIB170119	
2	MAIN OFFICE	LADD	36,000 BTU	EVEREST	FLOOR MOUNTED	36FSIF170535	
3	MANAGERS OFFICE	LADD	18,990 KJ/HR	EVEREST	WALL MOUNTED	20STD170368	
4	ROOM 1	LADD	1.0 HP	EVEREST	WINDOW	M10WDE176372	
5	ROOM 2	LADD	1.0 HP	EVEREST	WINDOW	M10WDE176812	
6	ROOM 3	LADD	1.0 HP	EVEREST	WINDOW	M10WDE176368	
7	MAIN OFFICE	LADD	38,000 BTU	KOPPEL	FLOOR MOUNTED	200-22410	
8	MAIN OFFICE	LADD	36,000 BTU	EVEREST	FLOOR MOUNTED	36FSIF170483	
9	OFFICE	LADD	25,030 KJ/HR	EVEREST	WALL MOUNTED	255TIB170120	

	BLDG 494						
1	LOBBY	OSD	18710 KJ/HR	GREE	WINDOW	200-22360	INVERTER
2	PASS AND ID	OSD	18710 KJ/HR	GREE	WINDOW	200-22478	INVERTER
3	WINDOW 1	OSD	2.0 HP	HISENSE	WALL MOUNTED	200-22282	
4	PICD LOBBY	OSD	60000 BTU	KOPPEL	FLOOR MOUNTED	200-22288	
5	PICD OFFICE	OSD	60000 BTU	KOPPEL	FLOOR MOUNTED	200-22290	
6	PICD LOBBY	OSD	60000 BTU	KOPPEL	FLOOR MOUNTED	200-22292	
7	PICD CASHIER	OSD	9000 BTU	TECO	WALL MOUNTED	ZM91900005	
8	PICD ID	OSD	9000 BTU	TECO	WALL MOUNTED	ZM91900049	
	BLDG 662						
1	2ND FLR. PDO	PDO	18710 KJ/HR	GREE	WINDOW	200-22224	INVERTER
2	2ND FLR. PDO	PDO	19300 KJ/HR	CONDURA	WINDOW	200-21089	
3	2ND FLR. PDO	PDO	18710 KJ/HR	GREE	WINDOW	200-22223	INVERTER
4	2ND FLR. MANAGER	PDO	18710 KJ/HR	GREE	WINDOW	200-22221	INVERTER
5	2ND FLR. CORPORATE PLAN	PDO	18710 KJ/HR	GREE	WINDOW	200-22222	INVERTER
6	2ND FLR. PDO	PDO	1.5 HP	HISENSE	WALL MOUNTED	200-22406	
7	2ND FLR. PDO STORAGE	PDO	19300 KJ/HR	CARRIER	WINDOW	200-11897	
8	2ND FLR. HRMD	LABOR DEPARTMENT	19300 KJ/HR	CARRIER	WINDOW	200-19328	
9	2ND FLR. LABOR	LABOR DEPARTMENT	19300 KJ/HR	CARRIER	WINDOW	200-15747	
10	2ND FLR. LABOR	LABOR DEPARTMENT	18710 KJ/HR	GREE	WINDOW	200-22483	INVERTER
11	HRMO	LABOR DEPARTMENT	19300 KJ/HR	CARRIER	WINDOW	200-21241	
12	HRMO	LABOR DEPARTMENT	19300 KJ/HR	CARRIER	WINDOW	200-21290	
13	2ND FLR. LABOR CONFERENCE	LABOR DEPARTMENT	1.0 HP	LG	WINDOW	200-20369	
14	2ND FLR. HRMO	LABOR DEPARTMENT	18710 KJ/HR	GREE	WINDOW	200-22481	INVERTER
15	2ND FLR. WDD	WDD	18710 KJ/HR	GREE	WINDOW	200-22342	INVERTER
16	2ND FLR. WDD	WDD	1.0 HP	CARRIER	WINDOW	200-19426	
17	2ND FLR. WDD	WDD	19300 KJ/HR	CARRIER	WINDOW	200-19030	
18	2ND FLR. TRAINING ROOM	TRAINING COUNTER	18710 KJ/HR	GREE	WINDOW	200-22343	INVERTER
19	2ND FLR. TRAINING ROOM	TRAINING COUNTER	19300 KJ/HR	CONDURA	WINDOW	200-11730	
20	2ND FLR. TRAINING ROOM	TRAINING COUNTER	1.0 HP	CARRIER	WINDOW	200-19844	
21	2ND FLR. TRAINING ROOM	TRAINING COUNTER	1.0 HP	LG	WALL MOUNTED	200-19124	
22	2ND FLR. HRMD	TRAINING COUNTER	19300 KJ/HR	CARRIER	WINDOW	200-00988	
23	CONFERENCE	ICT	1.0 HP	TECO	WALL MOUNTED	ZK71600071	
24	STORAGE	ICT	1.0 HP	TECO	WALL MOUNTED	ZM91900128	
25	MANAGER	ICT	1.0 HP	TECO	WALL MOUNTED	ZM91600085	
26	PANTRY	ICT	1.0 HP	TECO	WALL MOUNTED	ZK71600025	
27	OFFICE	ODABG	18000 BTU	TECO	WALL MOUNTED	ZK72100075	
28	OFFICE	ODABG	18000 BTU	TECO	WALL MOUNTED	ZK72100110	
29	OFFICE	ODABG	22000 BTU	TECO	WALL MOUNTED	ZK72200075	
30	BIDGB	BIDGB	2.5 HP	LG	WINDOW	N/A	INVERTER
31	PANTRY	BIDGB	2760 WATTS	TECO	WINDOW	N/A	INVERTER
32	DIVISION CHIEF	BIDGB	18000 BTU	TECO	WALL MOUNTED	ZK72100118	
33	OFFICE	ICT	36000 BTU	LG	LING MOUNTED CASSE	AVNQ36GM1A0	
34	OFFICE	BIDGB	22000 BTU	TECO	WALL MOUNTED	ZK72200061	
35	OFFICE	BIDGB	22000 BTU	TECO	WALL MOUNTED	ZK72200046	
36	HALLWAY	ICT	2760 WATTS	TECO	WINDOW	N/A	INVERTER
	BLDG 705						
1	BLDG 705	ACCOUNTING	18710 KJ/HR	GREE	WINDOW	200-22286	INVERTER
2	BLDG 705	ACCOUNTING	18710 KJ/HR	GREE	WINDOW	200-22285	INVERTER
	BLDG 896						
1	OFFICE	BID	1.5 HP	NATIONAL	WALL MOUNTED	200-20823	
2	OFFICE	BID	2.0 HP	TECO	WALL MOUNTED	LS18VCPH6	
3	OFFICE	BID	3TR	KOPPEL	FLOOR MOUNTED	200-22196	
4	CONFERENCE	BID	1.5 HP	SANYO	WALL MOUNTED	180275	
5	SDA	SDA	2.0 HP	HISENSE	WALL MOUNTED	200-22200	
6	SLS BIPLEI	BIDLEI	2.0 HP	HISENSE	WALL MOUNTED	200-22444	
7	MMBD	MMBD	2.0 HP	CARRIER	WINDOW	200-19160	
8	MANUFACTURING AND MARITIME	MANUFACTURING AND MARITIME	2.0 HP	HISENSE	WALL MOUNTED	200-22246	
9	MANUFACTURING AND MARITIME	MANUFACTURING AND MARITIME	2.0 HP	HISENSE	WALL MOUNTED	200-19502	
10	MANUFACTURING AND MARITIME	MANUFACTURING AND MARITIME	2.0 HP	CARRIER	WINDOW	200-18516	
11	MANUFACTURING AND MARITIME	MANUFACTURING AND MARITIME	2.0 HP	CARRIER	WINDOW	200-19444	
12	MANUFACTURING AND MARITIME	MANUFACTURING AND MARITIME	1.5 HP	CARRIER	WINDOW	200-19447	
13	RAC BIDLEI	BIDLEI	2.0 HP	GREE	WINDOW	200-22449	
14	RNM BIDLEI	BIDLEI	1.5 HP	GREE	WINDOW	200-22364	
	BLDG N						
1	TSG	MISO	18,710 KJ/HR	GREE	WINDOW	200-22363	INVERTER
2	TSG	MISO	19,300 KJ/HR	CARRIER	Window	200-12532	
3	TSG	MISO	1.0 HP	KELVINATOR	Window	200-00818	
4	TSG	MISO	19,300 KJ/HR	CARRIER	Window	200-18169	
5	TSG	MISO	1.0 HP	NATIONAL	Window	200-12005	
6	201	MISO	19,300 KJ/HR	CARRIER	Window	200-16973	
7	ARMIC	MISO	19,300 KJ/HR	CARRIER	Window	200-19347	
8	ARMIC	MISO	19,300 KJ/HR	CARRIER	Window	200-16921	
9	DNDM	MISO	9,300 KJ/HR	LG	Window	200-21005	
10	DNDM	MISO	9,300 KJ/HR	LG	Window	200-18692	
11	DNDM	MISO	18,710 KJ/HR	GREE	WINDOW	200-22362	INVERTER
12	CCO	MISO	1.0 HP	CARRIER	Window	200-18086	
13	CCO	MISO	3TR	CARRIER	FLOOR MOUNTED	200-20490	
14	201	MISO	60,000 BTU	KOPPEL	FLOOR MOUNTED	200-95911	
15	201	MISO	2.5 HP	CARRIER	WALL MOUNTED	200-20905	

16	RADIO STATION	MISO	1.0 HP	KOLIN	Window	N/A	
17	RADIO STATION STUDIO	MISO	24,000 KJ/HR	CARRIER	WALL MOUNTED	42KHAA34070	
18	RADIO STATION	MISO	2.5 HP	HISENSE	WALL MOUNTED	200-22412	
19	DNDM	MISO	60,000 BTU	KOPPEL	FLOOR MOUNTED	200-95910	
20	ADMIN OFFICE	MISO	2.0 HP	KOPPEL	WALL MOUNTED	200-95905	
21	RADIO STATION	MISO	1.0 HP	NATIONAL	Window	N/A	
KALAKLAN							
1	OFFICE	K TERMINAL	18710 KJ/HR	GREE	WINDOW	200-22374	INVERTER
2	OFFICE	K TERMINAL	1.0 HP	LG	WINDOW	200-21017	
QUARTERS 5000							
1	MASTER BED		18710 KJ/HR	GREE	WINDOW	200-22493	INVERTER
2	WALK IN CLOSET		19300 KJ/HR	CONDURA	WINDOW	200-20456	
3	ROOM		19600 KJ/HR	CARRIER	WINDOW	200-14322	
4	ROOM		19600 KJ/HR	CARRIER	WINDOW	200-19307	
5	ROOM		1.5 HP	CONDURA	WINDOW	200-13548	
6	ROOM		1.5 HP	CARRIER	WINDOW	200-18085	
7	ROOM		19300 KJ/HR	CONDURA	WINDOW	200-21085	
8	ROOM		1.0 HP	LG	WINDOW	802TAJD00260	
9	OFFICE		1.0 HP	KOPPEL	WALL MOUNTED	200-20317	
10	SALA		3 TR	CARRIER	FLOOR MOUNTED	200-19759	
11	DINNING AREA		18000 BTU	KOPPEL	WALL MOUNTED	200-19249	
REGULATORY							
1	TELECOM		1.0 HP	HISENSE	WALL MOUNTED	200-22316	
2	TELECOM		1.0 HP	HISENSE	WALL MOUNTED	200-22314	
3	TELECOM		5 TR	MIDEA	FLOOR MOUNTED	200-20001	
4	TELECOM		1.0 HP	MIDEA	WALL MOUNTED	200-20497	
5	TELECOM		1.0 HP	MIDEA	WALL MOUNTED	200-20007	
6	TELECOM		2.0 HP	MIDEA	WALL MOUNTED	200-20003	
7	TELECOM		2.5 HP	HISENSE	WALL MOUNTED	200-22318	
8	TELECOM		1.0 HP	HISENSE	WALL MOUNTED	200-22312	
9	MVRO		1.5 HP	HISENSE	WALL MOUNTED	200-22308	
10	MVRO		1.5 HP	HISENSE	WALL MOUNTED	200-22306	
11	MVRO		1.5 HP	HISENSE	WALL MOUNTED	200-22304	
12	CASHIER MVRO		1.0 HP	MIDEA	WALL MOUNTED	200-20495	
13	LOBBY		3 TR	CARRIER	FLOOR MOUNTED	200-22201	
14	ECOLOGY CENTER		60000 BTU	KOPPEL	FLOOR MOUNTED	200-22302	
15	ECOLOGY CENTER		3 TR	MIDEA	FLOOR MOUNTED	200-20487	
16	206	BPSD	5 TR	MIDEA	FLOOR MOUNTED	200-20477	
17	206	BPSD	5 TR	MIDEA	FLOOR MOUNTED	200-20479	
18	206	BPSD	1.0 HP	MIDEA	WALL MOUNTED	200-20481	
19	205	ACCREDITATION	3 TR	KOPPEL	FLOOR MOUNTED	200-20011	
20	205	ACCREDITATION	3 TR	KOPPEL	FLOOR MOUNTED	200-20012	
21	202 CONFERENCE	REGULATORY	2.5 HP	MIDEA	WALL MOUNTED	200-20471	
22	202 CONFERENCE	REGULATORY	2.5 HP	MIDEA	WALL MOUNTED	200-20469	
23	201	OFFICE OF THE SENIOR DEPUTY	2.5 HP	MIDEA	WALL MOUNTED	200-20474	
24	201	OFFICE OF THE SENIOR DEPUTY	2.5 HP	CARRIER	WALL MOUNTED	200-20013	
25	201	OFFICE OF THE SENIOR DEPUTY	3 TR	CARRIER	FLOOR MOUNTED	200-21202	
26	LOBBY	REGULATORY	5 TR	CARRIER	FLOOR MOUNTED	200-22298	
27	PROJECT MANAGEMENT	REGULATORY	2.0 HP	CARRIER	WALL MOUNTED	200-20463	
28	PROJECT MANAGEMENT	REGULATORY	2.0 HP	CARRIER	WALL MOUNTED	200-20461	
SBECC							
1	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18304	
2	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18339	
3	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18305	
4	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.13	
5	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18307	
6	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.12	
7	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.1	
8	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18341	
9	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.2	
10	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18343	
11	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18309	
12	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.11	
13	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18312	
14	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.3	
15	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18313	
16	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.10	
17	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18315	
18	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.9	
19	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.4	
20	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18345	
21	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.5	
22	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18347	
23	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.6	
24	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18349	
25	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.0	
26	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.7	
27	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18319	
28	HALL A	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU A1.8	
29	HALL A	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18317	
30	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18394	
31	HALL C	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU C1.4	
32	HALL C	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU C1.5	
33	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18392	

34	HALL C	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU C1.2
35	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18332
36	HALL C	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU C1.1
37	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18334
38	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18384
39	HALL C	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU C1.6
40	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18428
41	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18370
42	HALL C	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU C1.3
43	HALL C	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18330
44	HALL B	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18429
45	HALL B	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU B1.6
46	HALL B	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18430
47	HALL B	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU B1.5
48	HALL B	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU B1.4
49	HALL B	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18378
50	HALL B	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU B1.3
51	HALL B	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18338
52	HALL B	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU B1.2
53	HALL B	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18425
54	HALL B	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU B1.1
55	HALL B	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18441
56	LOBBY	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU J1.1
57	LOBBY	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU J1.2
58	LOBBY	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU J1.3
59	LOBBY	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU J1.4
60	LOBBY	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU J1.5
61	LOBBY	TOURISM	15 HP	LG	FLOOR MOUNTED	FCU J1.6
62	MEETING ROOM	TOURISM	15 HP	LG	FLOOR MOUNTED	GF-FCU 1
63	MEETING ROOM	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18369
64	MEETING ROOM	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18386
65	MEETING ROOM	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18429
66	MEETING ROOM	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18375
67	MEETING ROOM	TOURISM	15 HP	TECO	FLOOR MOUNTED	200-18350
68	RECEIVING AREA	TOURISM	10 TR	TECO	FLOOR MOUNTED	200-18367
69	CR	TOURISM	2.5 HP	LG	WALL MOUNTED	909HAUJ80622
70	CR	TOURISM	2.5 HP	LG	WALL MOUNTED	N/A
71	CR	TOURISM	2.5 HP	LG	WALL MOUNTED	N/A
72	CR	TOURISM	2.5 HP	TECO	WALL MOUNTED	B5040034
73	CR	TOURISM	2.5 HP	TECO	WALL MOUNTED	B5040172
74	ADMIN	TOURISM	10 TR	LG	FLOOR MOUNTED	2P-FCU2
75	ADMIN	TOURISM	10 TR	LG	FLOOR MOUNTED	2P-FCU4
76	CR	TOURISM	2.5 HP	TECO	WALL MOUNTED	B5030051
77	CR	TOURISM	2.5 HP	KOLIN	WALL MOUNTED	5924120155
78	2/F ADMIN	TOURISM	4 HP	N/A	CEILING MOUNTED CASSETTE	N/A
79	2/F ADMIN	TOURISM	4 HP	N/A	CEILING MOUNTED CASSETTE	N/A
80	2/F ADMIN	TOURISM	4 HP	N/A	CEILING MOUNTED CASSETTE	N/A
81	2/F ADMIN	TOURISM	4 HP	N/A	CEILING MOUNTED CASSETTE	N/A
82	2/F ADMIN	TOURISM	4 HP	N/A	CEILING MOUNTED CASSETTE	N/A
83	2/F ADMIN	TOURISM	4 HP	N/A	CEILING MOUNTED CASSETTE	N/A
84	2/F ADMIN	TOURISM	4 HP	N/A	CEILING MOUNTED CASSETTE	N/A
85	2/F ADMIN	TOURISM	15 HP	LG	FLOOR MOUNTED	N/A
86	2/F ADMIN	TOURISM	15 HP	LG	FLOOR MOUNTED	N/A
87	2/F ADMIN	TOURISM	15 HP	LG	FLOOR MOUNTED	N/A
88	2/F ADMIN	TOURISM	15 HP	LG	FLOOR MOUNTED	N/A
SEAPORT						
1	G07	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-19782
2	G08	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-19793
3	G10	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-20232
4	G11	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-19787
5	G04	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-19780
6	G02	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-20228
7	GROUND FLR. CONFERENCE	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-19791
8	2ND FLR. WAITING AREA	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20019
9	102 STATISTICS AND RECORD	SEAPORT DEPARTMENT	19600 KH/HR	CONDURA	WINDOW	200-22625
10	101	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	850-09547
11	101	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	FLOOR MOUNTED	850-07780
12	102 STATISTICS AND RECORD	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-20650
13	105 PANTRY	SEAPORT DEPARTMENT	1.5 HP	HITACHI	WALL MOUNTED	200-20244
14	105 OFFICE	SEAPORT DEPARTMENT	1.5 HP	HITACHI	WALL MOUNTED	200-20242
15	108	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20699-A
16	107	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-20015
17	107	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20017
18	107 CASHIER	SEAPORT DEPARTMENT	1.0 HP	HITACHI	WALL MOUNTED	200-17628
19	109	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-20044
20	2ND FLR CABLE ROOM SM.	SEAPORT DEPARTMENT	1.0 HP	HITACHI	WALL MOUNTED	200-19386
21	209 PORT ENGINEER	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-19893

22	209 PORT ENGINEER	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-19891	
23	204	SEAPORT DEPARTMENT	3TR	HITACHI	FLOOR MOUNTED	200-18654	
24	204	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	FLOOR MOUNTED	N/A	
25	209 PORT ENGINEER	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-19895	
26	209 PORT ENGINEER	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-19897	
27	CONFERENCE	SEAPORT DEPARTMENT	3TR	HITACHI	FLOOR MOUNTED	200-19399	
28	208 AGM	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-19880	
29	G01	SEAPORT DEPARTMENT	3 TR	HITACHI	FLOOR MOUNTED	200-20236	
30	DA FOR PORTS	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20047	
31	208 GM	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	N/A	
32	208 GM STAFF	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20020	
33	203 SDA	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-18648	
34	203 SECRETARY	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-18646	
35	PORT TRAFFIC	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20646	
36	PORT TRAFFIC	SEAPORT DEPARTMENT	27000 BTU	KOPPEL	WALL MOUNTED	200-22400	
37	304 MDH	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20644	
38	302 MS AND I	SEAPORT DEPARTMENT	1045 WATTS	CONDURA	WALL MOUNTED	200-23050	
39	302 MS AND I	SEAPORT DEPARTMENT	25600 KJ/HR	HITACHI	WALL MOUNTED	200-20648	
40	301 VTMS	SEAPORT DEPARTMENT	23206 KJ/HR	HISENSE	WALL MOUNTED	200-22398	
41	301 VTMS	SEAPORT DEPARTMENT	23206 KJ/HR	HISENSE	WALL MOUNTED	200-22396	
42	301 VTMS	SEAPORT DEPARTMENT	10.0 KW	DAIKIN	WALL MOUNTED	200-23176	
43	NSD	SEA PORT	2.0 HP	KOPPEL	WINDOW	200-21155	
44	NSD	SEA PORT	2.0 HP	KOPPEL	WINDOW	200-21154	
45	NSD	SEA PORT	2.0 HP	KOPPEL	WINDOW	200-21152	
46	NSD	SEA PORT	2.0 HP	KOPPEL	WINDOW	200-21158	
47	NSD	SEA PORT	1.5 HP	KOPPEL	WINDOW	200-21229	
48	NSD	SEA PORT	2.0 HP	KOPPEL	WINDOW	200-21159	
	SUBIC GYM						
1	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22256	
2	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22270	
3	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22258	
4	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22274	
5	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22260	
6	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22276	
7	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22278	
8	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22266	
9	Upper Deck	TOURISM	10 HP	CARRIER	Floor Mounted	200-22264	
10	Upper Deck	TOURISM	10 HP	TOSOT	Floor Mounted	9U97890000075	
11	Upper Deck	TOURISM	10 HP	TOSOT	Floor Mounted	9U97890000076	
12	Upper Deck	TOURISM	10 HP	TOSOT	Floor Mounted	9U97890000068	
13	Upper Deck	TOURISM	10 HP	TOSOT	Floor Mounted	9U97890000074	
14	Upper Deck	TOURISM	10 HP	TOSOT	Floor Mounted	63239904608	
15	Upper Deck	TOURISM	10 HP	TOSOT	Floor Mounted	9U978900000	
16	DUGOUT B	TOURISM	1.5 HP	LG	Wall mounted	907HANK83175	
17	DUGOUT B	TOURISM	1.5 HP	LG	Wall mounted	907HANK83151	
18	DUGOUT A	TOURISM	3TR	LG	Floor Mounted	811KCDG1HL66	
19	OFFICE	TOURISM	1.0 HP	LG	Wall mounted	907HAVN7Y847	
20	RW FEMALE CR	TOURISM	1.0 HP	LG	Wall mounted	907HAVN7Y812	
21	LW MALE CR	TOURISM	1.0 HP	LG	Wall mounted	907HABZ74845	
22	LW FEMALE CR	TOURISM	1.0 HP	LG	Wall mounted	907HAW577841	
	TIPO						
1	OFFICE	SEAPORT	18710 KJ/HR	GREE	WINDOW	200-22477	INVERTER
2	OFFICE	SEAPORT	1.0 HP	TECO	WALL MOUNTED	200-22468	
3	OFFICE	OSD	1.0 HP	TECO	WALL MOUNTED	N/A	
4	OFFICE	OSD	1.0 HP	TECO	WALL MOUNTED	N/A	
	TRANSPORTATION						
1	ADMIN OFFICE	TRANSPORTATION DEPT	1.5 HP	FEDDERS	WINDOW	200-19340	
2	ADMIN OFFICE	TRANSPORTATION DEPT	2.0 HP	HISENSE	WALL MOUNTED	200-22430	
3	LICENSING OFFICE	TRANSPORTATION DEPT	1.5 HP	CARRIER	WINDOW	200-14935	
4	FUEL CONCERN	TRANSPORTATION DEPT	2.0 HP	CARRIER	WINDOW	200-20071	
5	FUEL CONCERN	TRANSPORTATION DEPT	2.0 HP	HISENSE	WALL MOUNTED	200-22432	
6	FUEL CONCERN	TRANSPORTATION DEPT	1.0HP	CARRIER	WALL MOUNTED	200-17122	
7	DIVISION CHIEF	TRANSPORTATION DEPT	2.0 HP	CARRIER	WINDOW	200-22432	
8	CONFERENCE ROOM	TRANSPORTATION DEPT	1.0HP	LG	WINDOW	200-20687	
9	RECORD SECTION	TRANSPORTATION DEPT	1.5 HP	CARRIER	WINDOW	200-21086	
10	OFFICE OF MANAGER	TRANSPORTATION DEPT	2.0 HP	CARRIER	WINDOW	200-16986	
11	WAITING AREA	TRANSPORTATION DEPT	10 HP	CARRIER	FLOOR MOUNTED	200-17137	
12	CONFERENCE ROOM	TRANSPORTATION DEPT	1.0 hp	CARRIER	WALL MOUNTED	200-13170	
13	DISPATCHER	TRANSPORTATION DEPT	1.5 HP	HITACHI	WINDOW	1002847	
14	CANTEEN	TRANSPORTATION DEPT	1.5 HP	CONDURA	WINDOW	48005158	
15	OFFICE	TRANSPORTATION DEPT	2.0 HP	CARRIER	WALL MOUNTED	200-17223	
16	TOOL ROOM	TRANSPORTATION	19300 KJ/HR	CARRIER	WINDOW	200-19448	
	TRILLO BAY VILLAS						
1	ROOM 1	OFFICE OF THE CHAIRMAN	1.5 HP	N/A	WALL MOUNTED	N/A	
2	ROOM 1	OFFICE OF THE CHAIRMAN	1.5 HP	N/A	WALL MOUNTED	N/A	
3	ROOM 2	OFFICE OF THE CHAIRMAN	2 HP	N/A	WALL MOUNTED	N/A	
4	ROOM 2	OFFICE OF THE CHAIRMAN	2 HP	N/A	WALL MOUNTED	N/A	
5	ROOM 3	OFFICE OF THE CHAIRMAN	2 HP	N/A	WALL MOUNTED	N/A	
6	ROOM 3	OFFICE OF THE CHAIRMAN	2 HP	N/A	WALL MOUNTED	N/A	

	ASD (FORMER METROBANK)					
1	OFFICE	ARCHIVE	7.5 TR	N/A	FLOOR MOUNTED	N/A
	LABOR (SUBIC GYM)					
1	OFFICE	LABOR DEPARTMENT	2 HP	N/A	WINDOW	N/A
2	OFFICE	LABOR DEPARTMENT	2 HP	N/A	WALL MOUNTED	N/A
	TREASURY (REMY FIELD)					
1	OFFICE	TREASURY	2 HP	N/A	WALL MOUNTED	N/A
	TOURISM (REMY FIELD)					
1	OFFICE	TOURISM	1.5 HP	N/A	WALL MOUNTED	N/A
2	OFFICE	TOURISM	1.5 HP	N/A	WALL MOUNTED	N/A
	CHAPEL					
1	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
2	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
3	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
4	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
5	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
6	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
7	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
8	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
9	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
10	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
11	AUDITORIUM	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
12	ADORATION CHAPEL	TOURISM	2 HP	N/A	WALL MOUNTED	N/A
13	ADORATION CHAPEL	TOURISM	2 HP	N/A	WINDOW	N/A
14	PRIEST'S STUDY ROOM	TOURISM	1.5 HP	N/A	WINDOW	N/A
15	PRIEST'S STUDY ROOM	TOURISM	1.5 HP	N/A	WINDOW	N/A
16	PRIEST'S STUDY ROOM	TOURISM	1.5 HP	N/A	WINDOW	N/A
17	PRIEST'S STUDY ROOM	TOURISM	1.5 HP	N/A	WALL MOUNTED	N/A
18	QUARTERS	TOURISM	1.5 HP	N/A	WALL MOUNTED	N/A

Prepared by:


FREDERICK E. GARCIA

Secretary I/P&E, Maintenance Division
Maintenance and Transportation Dept.



EDWIN N. PELAGIO

Engineer II, Maintenance Division
Maintenance and Transportation Dept.

Checked and Reviewed by:


ENGR. JOSE M. CRUZ JR.

Division Chief III, Maintenance Division
Maintenance and Transportation Dept.

Approved by:


CARLITO C. CRUZ

Department Manager
Maintenance and Transportation Department